

From: [Jon Strand](#)
To: [Brad Roy](#)
Cc: [Bradley Vick](#)
Subject: Ellsworth Water
Date: Monday, August 7, 2023 10:22:17 AM

Brad,

After reviewing the projected water demands, well capacities and pump runtimes provided for warm weather months, it appears that the wells have adequate capacity for an additional demand of 23,000 gallons per day.

Jon Strand, PE
Project Manager
CBS Squared, Inc.
[770 Technology Way, Suite 1A](#)
[Chippewa Falls, WI 54729](#)
715.829.7979
jstrand@cbssquaredinc.com

Find us on [Facebook](#) and [LinkedIn](#)!

The information contained in this e-mail (and any attachments) is confidential and may not be used by anyone other than the addressee. If you are not this intended recipient please notify us immediately